

Sampling Results

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The tables below show only those contaminants that were detected in the water. The state requires us to monitor for certain substances less often than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

PRIMARY REGULATED CONTAMINANTS							
Microbiological Contaminants							
CONTAMINANT AND UNIT OF MEASUREMENT	DATE OF SAMPLING (MO./YR.)	MCL VIOLATION (YES/NO)	TOTAL NUMBER OF POSITIVE SAMPLES FOR THE YEAR	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION	
Fecal coliform and E.coli [in the distribution system] ¹ (# positive samples)	09/13/2011	Yes	1	0	0	Total Coliform; E Coli	
Total coliform (# positive samples)	12/13/2011	No	2.5% (Highest Monthly Percentage)	0	>5% of monthly samples	Naturally present in the environment	
Volatile Organic Contaminants							
CONTAMINANT AND UNIT OF MEASUREMENT	DATE OF SAMPLING (MO./YR.)	MCL VIOLATION (YES/NO)	LEVEL DETECTED	RANGE OF RESULTS	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Dichloromethane ² (ppb)	May 19, 2011	No	0.8	NA	0	5	Discharge from pharmaceutical and chemical factories

¹This matter is now considered closed by the Broward County Health Department.

²Regulatory Detection Limit is 0.5.

Definitions

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

NA: Not applicable

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

About Our Violation

Our water system failed to collect repeat bacteriological samples within 24 hours after distribution samples on 09/13/2011 were total coliform-positive and E-Coli positive, and we could not be sure of the quality of the water at that time.

Fecal coliforms and *E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Fact or Fiction

Tap water is cheaper than soda pop. (*Fact: You can refill an 8 oz. glass of tap water approximately 15,000 times for the same cost as a six-pack of soda pop. And, water has no sugar or caffeine.*)

Methods for the treatment and filtration of drinking water were developed only recently. (*Fiction: Ancient Egyptians treated water by siphoning water out of the top of huge jars after allowing the muddy water from the Nile River to settle. And, Hippocrates, known as the father of medicine, directed people in Greece to boil and strain water before drinking it.*)

A typical shower with a non-low-flow showerhead uses more water than a bath. (*Fiction: A typical shower uses less water than a bath.*)

Water freezes at 32 degrees Fahrenheit. (*Fiction: You can actually chill very pure water past its freezing point (at standard pressure) without it ever becoming solid.*)

The Pacific Ocean is the largest ocean on Earth. (*Fact: The Atlantic Ocean is the second largest and the Indian Ocean is the third largest.*)

A single tree will give off 70 gallons of water per day in evaporation. (*Fact*)

Where Does My Water Come From?

In 2011, Coral Springs Improvement District treated and delivered to the District 1.308 billion gallons of water. The water source for the District is the Biscayne Aquifer, an underground geological formation and a reliable source of high-quality water since the early 1920's. The water is withdrawn and pumped to the District Treatment Plant by 11 "raw water" wells located within the District.

What's a Cross-connection?

Cross-connections that contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems), or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand), causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools, or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continuously jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed all industrial, commercial, and institutional facilities in the service area to make sure that all potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

For more information, review the Cross-Connection Control Manual from the U.S. EPA's Web site at <http://water.epa.gov/infrastructure/drinkingwater/pws/crossconnectioncontrol/index.cfm>. You can also call the Safe Drinking Water Hotline at (800) 426-4791.

The Water Treatment Process

The treatment process consists of a series of steps. First, raw water is drawn from the Biscayne Aquifer from preselected wells and sent to an up-flow clarifier where a calculated dose of chlorine is injected. After passing over a cascade tray which allows for oxidation of the iron and sulfur levels that are present in the water, the water then goes through the lime softening process, which removes 75-85% of the hardness, a characteristic of water caused primarily by the salts of calcium and magnesium. A coagulating agent is then added which allows the small particles to adhere to one another (called "floc"), making them heavy enough to settle into a basin from which the sediment is removed. Chlorine is again added for disinfection. At this point, the water is filtered through layers of fine coal and silicate sand. As smaller, suspended particles are removed, the turbidity is removed and clear water emerges.

Chlorine is added again as a precaution against any bacteria that may still be present. (We carefully monitor the amount of chlorine, adding the lowest quantity necessary to protect the safety of your water without compromising taste.) Finally, fluoride (used to prevent tooth decay) and a corrosion inhibitor (used to protect distribution system pipes) are added before the water is pumped to sanitized, above-ground storage tanks, and into your home or business.

Q & A

Who uses the most water?

On a global average, most freshwater withdrawals—69 percent—are used for agriculture, while industry accounts for 23 percent and municipal use (drinking water, bathing and cleaning, and watering plants and grass) just 8 percent.

How much water does a person use every day?

The average person in the U.S. uses 80 to 100 gallons of water each day. During medieval times, a person used only 5 gallons per day.

Should I be concerned about what I'm pouring down my drain?

If your home is served by a sewage system, your drain is an entrance to your wastewater disposal system and eventually to a drinking water source. Consider purchasing environmentally friendly home products whenever possible, and never pour hazardous materials (e.g., car engine oil) down the drain. Check with your health department for more information on proper disposal methods.

How long does it take a water supplier to produce one glass of water?

It can take up to 45 minutes to produce a single glass of drinking water.

How much emergency water should I keep?

Typically, 1 gallon per person per day is recommended. For a family of four, that would be 12 gallons for 3 days. Humans can survive without food for 1 month, but can only survive 1 week without water.

Where does a water molecule spend most of its time on Earth?

In a 100-year period, a water molecule spends 98 years in the ocean, 20 months as ice, about 2 weeks in lakes and rivers, and less than a week in the atmosphere.

How many community water systems are there in the U.S.?

About 53,000 public water systems across the United States process 34 billion gallons of water per day for home and commercial use. Eighty-five percent of the population is served by these systems.